

## POTRDILO O PRESKUŠANJU TEST CERTIFICATE

Št. potrdila:  
Certificate No.: **IZV- 1396/11**

Veljavnost:  
Validity: **15 June. 2014**

Proizvajalec:  
Manufacturer: **JAKŠA MAGNETNI VENTILI d.o.o.,  
Šlandrova 8, 1231 Ljubljana -Črnuče**

Proizvod:  
Product: **ELEKTROMAGNETNI VENTILI ZA PLIN  
ELEKTROMAGNETIC VALVES FOR GAS**

Standard:  
Norm: **SIST EN 161: 2007 Samodejni zaporni ventili za plinske gorilnike in plinske aparate  
Automatic shut-off valves for gas burners and gas appliances**

Tip model:  
Types, Model: **D240, D224, PL3, PL10  
M2521, M2621, M275, M282  
PV4NC, PV5NC, PV6NC, PV7NC, PV8NC  
PV4, PV5, PV6, PV7, PV8**

### Izjava / Declaration:

Preskusni vzorci, ki predstavljajo zgoraj navedene tipe proizvoda so bili preskušani in pregledani na željo naročnika. Preskus je bil izveden v skladu s standardom EN 161 (točka 7.2, 7.11, 7.12 in 7.15).  
*Test samples that represent the above-mentioned types of product have been tested and examined the client's wishes. The test was carried out in accordance with EN 161 ( paragraph 7.2, 7.11, 7.12 and 7.15).*

Poročilo št.: Test report No.: **1564/E-11**

Datum / Date : **16 June. 2011**

### Zaključek / Conclusion:

Ugotovljeno je bilo, da preskusni vzorci izpolnjujejo tehnične zahteve zgoraj navedenega standarda.  
*It was found that the test samples meet the technical requirements of the above standard.*

Opomba : /  
Note:

Vodja laboratorija:  
Head of Laboratory:  
**Andrej Smonkar, dipl.univ.ing.**

Ljubljana, 16 June, 2011  
Place, date.:

ea

